



# Precision Environmental Monitoring in Data Centers

Data centers are the backbone of modern digital infrastructure, requiring unrelenting uptime and efficiency. While power and cooling systems are often the primary focus, the precision of the sensors checking or monitoring these systems is equally vital.

In the high-density environment of a modern data center, thermal management is a constant balancing act. Operators must maintain conditions that prevent equipment failure while minimizing ever more costly energy consumption. The margin for error is slim. Inaccurate environmental data can lead to two extremes:

1. The major cost of system downtime resulting from catastrophic hardware failure due to overheating, corrosion, condensation, contamination, static discharge; SLA breaches
2. Excessive operational expenses due to over-cooling

While temperature and humidity are the most fundamental metrics, advanced Indoor Air Quality (IAQ) testing and monitoring is highly beneficial for maximizing air quality in data centers. GrayWolf Environmental Meters provide highly reliable particle and gas measurements, as well as %RH and °C/°F, in portable and continuous monitoring configurations. These instruments can also be used to verify if lower cost fixed sensors, interfaced to Building Management Systems (BMS), report accurate values to the control systems.

**Particulate Matter (PM):** Dust and fine particles can clog server fans and heat sinks, acting as insulators that trap heat. They can accumulate on circuit boards causing interference and short circuiting. Detecting spikes in PM allows for early detection of filter bypass or other contamination issues, as well as scheduling timely filter changes before cooling efficiency drops.

**Particulate Guidelines:** While ASHRAE does not specify a microgram per cubic meter ( $\mu\text{g}/\text{m}^3$ ) particle limit for every scenario, they recommend adhering to the following U.S. EPA-based thresholds to avoid equipment corrosion and failure:

PM2.5: Should be kept below  $25 \mu\text{g}/\text{m}^3$ . Note: per some other data center industry recommendations, below  $15 \mu\text{g}/\text{m}^3$

PM10: Should be kept below  $50 \mu\text{g}/\text{m}^3$



However, data centers are usually recommended to, at minimum, meet ISO-14644-1 Class 8 cleanliness standards which can be verified using GrayWolf's range of Particle Meters.

A substantial portion of the energy use in data centers, perhaps as much as half, is dedicated to cooling the computer equipment. The data-center cooling load can be reduced by a substantial fraction when large amounts of outside air are used to cool internal loads during favorable weather conditions. However, many owners and operators are reluctant to use this cooling technique owing to concerns about the risk of equipment failure posed by introducing outdoor particulate matter into data-center buildings\*.

\*Particle Concentrations in Data Centers, UC Berkeley, Lawrence Berkeley National Laboratory, Et al., Elsevier 2008

**Gaseous Contaminants:** When outdoor air quality is poor, especially in industrial areas, corrosive gases such as sulfur dioxide, nitrogen oxides, (i.e. NO, NO<sub>2</sub>), ammonia, chlorine, hydrogen sulfide, or others can enter the facility. Monitoring these pollutants helps prevent the degradation of copper and silver interconnects within servers.

ANSI/ISA-71.04-2013 *Environmental Conditions for Process Measurement and Control Systems; Airborne Contaminants* lists the following gases of concern affecting electronic equipment, including process measurement and control systems, data communications and IT hardware, and other electronics.





Contaminant concentrations versus severity levels					
Severity level	G1 Mild	G2 Moderate	G3 Harsh	GX Severe	
Gas Concentration† (ppb)					
Contaminant					
Group A	H <sub>2</sub> S	<3	<10	<50	≥50
	SO <sub>2</sub> , SO <sub>3</sub>	<10	<100	<300	≥300
	Cl <sub>2</sub>	<1	<2	<10	≥10
	NO <sub>x</sub>	<50	<125	<1,250	≥1,250
Reactive Species ‡					
Group B§	HF	<1	<2	<10	≥10
	NH <sub>3</sub>	<500	<10,000	<25,000	≥25,000
	O <sub>3</sub>	<2	<25	<100	≥100

† Parts per billion by volume (ppbv) average for test period for the gases in Groups A and B.

‡ Group A contaminants often occur together, and the reactivity levels include the synergistic effects of these contaminants.

§ The synergistic effects of Group B contaminants are not known at this time.

While mild/moderate ISA concentration levels are not achievable for all sensors (sampling and lab analysis might be required to verify some of the lowest levels), many GrayWolf supplied sensors do achieve those low concentration limits, and the ones that don't, can be used to screen for presence of those gas contaminants while accurately identifying Harsh/Severe levels.

**Humidity Control:** Relative humidity (%RH) must be maintained within a tight range to avoid two distinct threats:

- **Low and rapidly changing Humidity (Static Discharge):** If the air becomes too dry (typically below 40% RH), the risk of Electrostatic Discharge (ESD) increases exponentially. A single static shock can permanently destroy sensitive microprocessors and storage media. Accurate low-end humidity sensing is the only defense against this invisible killer.
- **High Humidity (Corrosion and Condensation):** If the air is too moist, it risks condensation on internal components, leading to short circuits. Furthermore, high humidity accelerates "corrosion creep" on printed circuit boards. High-accuracy sensors are required to calculate the Dew Point precisely to ensure cooling coils do not introduce moisture into the airstream.

**Humidity Guidelines:** ASHRAE TC 9.9 *Data Center Equipment Thermal Guidelines and Best Practices, 2016* recommends 40 %RH to 60 %RH, -9°C to 15°C Dew Point. Note that these values assume Standard Atmospheric Pressure (Sea Level). In special circumstances ASHRAE allows a wider %RH range.

Using Barometric Pressure (BP) Compensated Humidity Ratio

ASHRAE TC 9.9 suggests that the barometric pressure influence of altitude up to 3050m (10,000ft) on moisture levels can be overlooked. But for optimum accuracy, BP can be corrected for.

Humidity ratio (also called mixing ratio or moisture content) is the mass of water vapor present in moist air divided by the mass of dry air in that same sample.

By using the GrayWolf AdvancedSense® XM meter or WolfPack® XM monitor, which each incorporate a barometric pressure sensor and can be equipped with a temperature and humidity sensor, you can calculate the maximum Humidity Ratio for the safe operation of Servers in a Data Center. When calculating Humidity Ratio with an AdvancedSense/WolfPack XM, the measured barometric pressure is used in the calculation, so no conversion is necessary at different altitudes.

**Differential Pressure (ΔP):**



AdvancedSense XM with optional ΔP Top View

An accurate portable digital manometer can be highly useful for testing filter pressure drops to determine if the filter is due for replacement. And when a contamination event occurs, they can be invaluable to help locate pressure breaches.

GrayWolf meters offer a dual auto-ranging sensor design with auto-zeroing for *exceptional* low-end ΔP accuracy (± 0.1 Pa ±1% rdg), yet a wide range (±10K Pa). Choose from the Zephyr™ XM (with ΔP built-in as standard) or

the AdvancedSense XM (with  $\Delta P$  optional). Both meters also interface to optional thermal anemometers and/or pitot tubes for outstandingly accurate air velocity measurement over a wide very range.



Using the AdvancedSense XM meter, a DirectSense<sup>®</sup> XM probe equipped with Temperature and Humidity sensors, optional NO, NO<sub>2</sub> and SO<sub>2</sub> sensors plus a GrayWolf PC-3500 Particulate Meter you can measure key parameters needed to maintain optimum conditions in a data center. Additional sensors, (e.g., NH<sub>3</sub>, H<sub>2</sub>S, Cl<sub>2</sub>, O<sub>3</sub>, HF, TVOCs) can be added for unusual environments. The purpose-built AdvancedSense XM can be substituted with a Windows, Android or iOS device in some circumstances.

GrayWolf probes and particulate meters are versatile tools designed for both hand-held spot checks and semi-permanent monitoring. Additionally, they can upload data directly to the GrayWolfLive<sup>®</sup> cloud application, sending SMS or e-mail alerts whenever non-optimal conditions are detected.

Alternatively, the new WolfPack XM monitor combines GrayWolf's range of measurements into a single unit.



*WolfPack XM portable (or fixed) monitor with Particle, Temp/%RH + 6 gas sensor modules installed*

Investing in professional-grade, high-accuracy sensors offers a tangible return on investment (ROI):

- **Energy Savings:** Accurate data allows operators to run the facility closer to the upper limits of ASHRAE recommendations safely, very significantly reducing cooling costs.
- **Asset Protection:** Preventing a single server rack failure due to environmental stress often covers the cost of the entire monitoring system.
- **Compliance:** Many Service Level Agreements (SLAs) require proof of environmental stability.
- **Construction Monitoring and Verification:** Test that conditions during and post construction achieve intended results.
- **Broader Utilization:** The same instruments can be used for wider HVAC, Facility Management testing.
- **Future Expansion:** Additional parameters and/or features may easily be added to the instrument system.

For More Information:

Tel: 1-203-402-0477

SalesTeam@GrayWolfSensing.com

[GrayWolfSensing.com](http://GrayWolfSensing.com)

U.S.A. (WORLDWIDE HEADQUARTERS)

GrayWolf Sensing Solutions, LLC

6 Research Drive, Shelton, CT 06484 USA

IRELAND

GrayWolf Sensing Solutions, LTD

Annacotty Industrial Park, Unit 1C

Annacotty, Co. Limerick, V94 PR2Y IRELAND

